

No Objection Certificate

Subject: Fire and Rescue Department Chengalpattu Fire and Rescue Station to issue certificate of inadmissibility to run a school

View: 1. Government Order No.: 122 School Education (2) Department Date: 14.09.2004
 2. Government Order No.: 123 School Road (2) Department Date: 14.09.2004.
 3. **The Principal, ATHENA GLOBAL SCHOOL, THIRUKALUKUNDRAM TALUK, Chengalpattu - District** Application Date: 03.04.2025

As per the application as per Exhibit 1, 2 Government Gazette and Exhibit -3, S.F.NO,102/1B2,1B4B,1B5B,1B5C, 185D&102/53 KEEZHAVEDU VILLAGE, THIRUKALKUNDRAM TALUK, CHENGALPATTU-DISTRICT ATHENA GLOBAL SCHOOL was inspected by the Special Station Officer Naidangadurai on 04.04.2025. There is no objection from the point of view of disaster management and rescue work to grant permission to run the school at this location.

Conditions

1. This permit is valid for three years from the date of issue. It must be renewed thereafter.
2. The fire suppression systems, safety measures and other measures shall be maintained in good condition at the site as per the National Building Code of India 2005, Indian Standards and other government rules.
3. As per Government Order No. 713 Internal (Police 17) Department Date: 17.08.2005, steps should be taken to provide basic firefighting and rescue training to the security personnel of the concerned institutions.
4. Adequate fire prevention equipment should be installed and maintained in the company.
5. A 350 LPM pump and a 10000-meter capacity overhead water tank with a HOSE REEL SYSTEM should be installed at the rate of one for every 1,000 square feet
6. A firefighter or a team of fire-trained personnel should be appointed to ensure that all fire-fighting equipment is well maintained.
7. Action will be taken to conduct a mock drill in the company in consultation with the nearest fire department so that all employees working in the company can become familiar with firefighting and rescue operations.

Office seal

Special Station Officer
 Fire Rescue Station
 Chengalpattu

From

The Principal
 ATHENA GLOBAL SCHOOL,
 S.F.NO:102/1B2,1B4B, 1B5B, 1B5C,185D&102/53 KEEZHAVEDU VILLAGE,
 THIRUKALKUNDRAM TALUK, CHENGALPATTU-DISTRICT

Copy: 1. Deputy Director North Western Zone. Vellore
 2. District Officer, Chengalpattu.
 3. Regarding Licensing Officer

Assistant District Officer Fire and Rescue Station Chengalpattu



D. Sasikumar 26.04.2025
D. SASIKUMAR, B.A.B.L.,
ADVOCATE & NOTARY PUBLIC
 MS. No: 280/2002
 Taluk Office Road, Madurantakam,
 Chengalpattu District-603 306.